



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

NT Window, Inc.
2900 W. Seminary Dr.
Ft. Worth, TX 76133

Attn: Luis Vega

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATIONS | | RECORD OF PRODUCT TESTED | | | |
|--|---|--------------------------|---|--|--|
| AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1372x1956 (54x77)-H Negative Design Pressure = -60 psf | | AAMA 506 | | | |
| COMPANY AND CODE | Missile Level: D Rating: +50/-60, 54x77 Wind Zone: 3 Rating above conforms to the requirements of: ASTM E1886 and E1996 | CPD NO. | SERIES MODEL & PRODUCT DESCRIPTION | MAXIMUM SIZE TESTED | |
| NT Window, Inc. Code: NT | | 20161 | G110 SH (FIN & FINLESS) (PVC)(O/X)(OG) (INS 0.090" PVB LAM GL) (MODIF)(REINF)(TILT) (ASTM) | <u>FRAME (mm)</u> 1372 x 1956 (4'6" x 6'5") | <u>SASH (mm)</u> 1280 x 965 (4'2" x 3'2") |

This Certification will expire **July 12, 2027 (extended from July 12, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Intertek B&C

Report No: **G8257.05-501-44**

Date of Report: **April 25, 2022**


Missile Impact Test & Report By:

Intertek B&C

Report No: **G8257.06-501-44**

Date of Report: **April 25, 2022**

Evaluated for Certification: **May 2, 2022**


Associated Laboratories, Inc.

Authorized for Certification: **May 2, 2022**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)